



Report No.:
31562502.001

Page 2 of 48

Client:	Capstone Turbine Corporation 21211 Nordhoff Street Chatsworth, CA 91311	Contact: Tel: Fax: e-mail:	Rey Tuscano 818-734-5353 818-734-5320 rtuscano@capstoneturbine.com
Identification:	MicroTurbines	Serial No.:	Not Serialized
Test item:	C65	Date Test Completed:	09/11/2015
Testing location:	Capstone Turbine Corporation 16640 Stagg Street Van Nuys, CA 91406		
Test specification:	Immunity: EN61000-6-2:2005, VI Part 7 GL 2012 EN61000-4-2:2009, EN61000-4-3:2006+A2:2010, EN61000-4-4:2012, EN61000-4-5:2006, EN61000-4-6:2009, EN61000-4-8:2010, EN61000-4-11:2004		
Test Result:	The above product was found to be Compliant to the above test standard(s)		
tested by: Randy Sorrenti		reviewed by: Dave Hollis	
14 September 2015 _____ Date Name Signature		14 September 2015 _____ Date Name Signature	
Other Aspects:	The manufacturer requested that only immunity tests be performed on the C65 and that the ESD contact discharge be performed at $\pm 6\text{kV}$ per the VI Part 7 GL 2012 standard. TUV Rheinland is not accredited to perform tests to VI Part 7 GL 2012 and therefore, is not in the TUV Rheinland scope of A2LA accredited standards.		
 			
Testing Cert #3331.01			

The test results contained in this report refer exclusively to the product(s) presented for testing. No liability may be assumed for models or products not referred to herein. This test report may not be published or duplicated in part without permission of the testing body. This test report by itself does not constitute authorization for the use of any TÜV Rheinland test mark. The report must not be used by the client to claim product certification, approval, or endorsement by A2LA.